


SECTION A-A

NOTES:

1. CULVERT MUST BE DUAL-WALL HDPE WITH SMOOTH INTERIOR FINISH IN ACCORDANCE WITH CSA B182.8.
2. UNLESS OTHERWISE STATED, HDPE CULVERT TO BE MINIMUM 400 mm IN DIAMETER.
3. CULVERT MUST HAVE MINIMUM STIFFNESS OF 320 kPa AT 5% DEFLECTION IN ACCORDANCE WITH ASTM D2412.
4. CULVERT ENDS MUST EXTEND BEYOND ENTRANCE AT A MAXIMUM OF 2:1 SLOPE AND SIDE SLOPES STABILIZED WITH SOD.
5. THE PIPE SHALL BE JOINED WITH AN EXTERNAL SPLIT COUPLER WITH GASKET THAT WILL NOT RESTRICT FLOW AND WILL PREVENT SOIL FROM ENTERING THE CULVERT PIPE.
6. ENTRANCES SHALL BE PAVED FROM THE EDGE OF THE TRAVELLED ROAD TO THE PROPERTY LINE WITH A BASE LIFT OF 40 mm OF HL8 AND A SURFACE LIFT OF 25 mm HL3.
7. IF CURB OR SIDEWALK CUT/REMOVAL/MODIFICATION IS REQUIRED THE WORK MUST BE DONE BY THE TOWN. THE APPLICANT WILL BE CHARGED THE COST OF THE WORK PLUS 15% ADMINISTRATION FEE.



THE CORPORATION
OF THE
TOWN OF GEORGINA
REGIONAL MUNICIPALITY OF YORK

RURAL ENTRANCES

DATE:	MAY 2021	SCALE:	N.T.S.
DRAWN:	O.S.		GR-9
CHKD. BY:	Z.A.		METRIC

1	ADHERES TO RD-7	MAY '21	
No.	REVISIONS	DATE	APP'D